
ENERGY SAVING OPPORTUNITIES SURVEY ESOS

West Point
Pre-Final Submittal

Contract No. DACA 31-81-C-0112

AUGUST 1986



For The Baltimore District Corps of Engineers

VOLUME I of VI NARRATIVE REPORT

BERNARD JOHNSON INCORPORATED ARCHITECTS ENGINEERS PLANNERS 6500 ROCK SPRING DR. BETHESDA, MARYLAND 20817

DEPARTMENT OF THE ARMY

CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS P.O. BOX 9005 CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO ATTENTION OF:

TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited. Distribution A. Approved for public release.

Marie Wakeffeld, Librarian Engineering

EXECUTIVE SUMMARY

I. INTRODUCTION

In the winter of 1980, the Army Corp of Engineers (COE), Baltimore District, advertised through the Commerce Business Daily for the services of an A/E firm with expertise in performing energy conservation surveys. The services of Bernard Johnson Incorporated (BJI) were retained in May, 1981, under contract number DACA-31-81-C-0112.

The purpose of this contract is to investigate a number of buildings, identified within the scope of work, for a set of energy conservation projects and determine their economic feasibility on a life-cycle basis.

Notice to proceed for West Point was issued by the Baltimore COE on September 2, 1983. Field surveys began in October of 1983 leading to preliminary submittal in January, 1984. The preliminary report provided the user with the results of the screening analysis of the projects within the scope of work based on the surveys. The Interim report submitted in August 1984 included energy saving and cost analyses representing approximately 70% of the entire effort.

This report represents the Pre-Final submittal of West Point Energy Savings Opportunities Survey (ESOS). It is an update of the Interim Report, which incorporates the review comments, as well as, completes over 95% of all saving and cost calculations for the energy conservation options for each building and provides programming documentation.

Developed projects have resulted in total annual energy savings of 176,000 MBTU which constitutes nearly 11.3% of the total energy consumption of West Point, at an estimated construction cost of \$3,838,000. Implementation of energy conservation options are expected to produce an annual dollar saving on the order of \$1,154,000.

DTIC QUALITY INSPECTED 2

19971023 101

West Point Pre-Final Report has been organized into five volumes:

- o Volume I has been subdivided into five sections.
 - Section 1 Provides all the background information, methods of approach, and the economic parameters used to develop the projects.
 - Section 2 Provides a brief description for every building within the scope of work, including the architecture of the building and the HVAC systems utilized. Additionally, building description section is used to account for all the projects within the scope of work and the results of the analyses. Section 2 also provides the summary of the results in a tabulated fashion.
 - Section 3 Provides the energy consumption and cost figures for West Point.
 - Section 4 Provides the report distribution list.
 - Section 5 Provides the base site plan

o Volumes II and III

Provides 1391 and 4283 programming documents for all projects which were determined to be economically feasible.

o Volumes IV, V, and VI

Provide the method of calculations, all the back-up calculations including energy savings analyses, cost estimates, life-cycle cost analyses.

II WEST POINT ENERGY CONSUMPTION

A summary of West Point facilities energy consumption for FY-81, FY-82, and FY-83 is shown in Table 1. This table indicates that energy consumption at the installation has dropped from FY 81 to FY 83 by 2.7%.

Figure 1 illustrates the total fixed facilities energy use at West Point by fuel type during FY 83. Electricity accounted for 37.9% of the total energy used, while natural gas accounted for 6.6%, oil #2 6.6% and oil #6 48.8% of the total energy consumption.

FIGURE 1

WEST POINT ENERGY CONSUMPTION BREAKDOWN FISCAL YEAR 1983 (MBTU)




TABLE 1
West Point's Energy Use
Fiscal Year 81 through Fiscal Year 83

FUEL TYPE	FY 81	FY 82	FY 83
	(MBTU)	(MBTU)	(MBTU)
Electricity Natural Gas Fuel Oil #2	581,700	596,800	614,500
	127,800	128,500	108,700
	108,200	120,200	107,200
Fuel Oil #6 TOTAL	850,100	856,500	791,600
	1,667,800	1,702,000	1,622,000

III. ENERGY CONSERVATION MEASURES DEVELOPED

Energy Savings Opportunities Survey (ESOS) conducted at West Point required investigation of a number of energy conservation measures. A total of 195 projects were found to be economically feasible based on life-cycle-cost analysis of about 460 projects. The feasible projects were then packaged, based on similarities, into 1391 and 4283 programming documents. A total of twelve 1391's and five 4283's were developed, which have been presented in Volumes II and III of this report.

Table 3 provides tabulated results of the feasible projects on a building basis, prioritized in the order of descending Savings-Investment-Ratio (SIR).

Table 4 provides tabulated results of the feasible projects from Table 3, which were packaged into 1391's and 4283's. The projects have been prioritized on the order of descending Savings-Investment-Ratio (SIR).

TABLE 2

PRIORITIZED LISTING OF FEASIBLE PROJECTS ON A BUILDING BASIS

		COST	SAVII	NGS		
Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}^2}{\text{YR}}$	SIR	Feasible? (Yes/No)
149	Hot Water Temp Reduction	6	17.83	207	151.2	Yes
600	Hot Water Temp Reduction	11	4.8	57	18.1	Yes
601	Air Volume Reduction	15,860	2,967.8	8,205	13.2	Yes
	Enthalphy Economizer	30,364	1,069.2	2,956	2.9	Yes
	Outside Air Reduction	10,997	846.6	2,340	2.1	Yes
603	Air Volume Reduction	597	342	8,321	40.5	Yes
	Outside Air Reduction	11,267	3,743	90,998	28.5	Yes
	Induction Kitchen Hood	21,828	1,719	41,825	7.0	Yes
	Enthalpy Economizer	8,677	656	15,961	6.7	Yes
	Piping Insulation	628	23.05	560	3.2	Yes
	Multi-Set Back	12,011	364	8,856	2.7	Yes
	Lighting	25,355	515.6	12,544	1.1	Yes
	Inside Insulation	32,546	369.96	9,001	1.0	Yes
604	High Efficiency Fluorescent	5,520	175.9	4,343	1.8	Yes
605	H.W. Temp. Reduction	6	8.05	164	82.0	Yes
	Zone Control	4,410	132	2,677	2.6	Yes
	Multi-Set Back	15,141	271	5,497	1.6	Yes
606	Outside Air Reduction	3,995	753.47	6,535	16.4	Yes
618	Roof Insulation	14,523	172.96	12,267	1.0	Yes

TABLE 2

		COST	SAVII	NGS		
Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}^2}{\text{YR}}$	SIR	Feasible? (Yes/No)
620	Hot Water Temp Reduction	6	14.29	234	145.4	Yes
	Piping Insulation	341	56.33	1,055	15.6	Yes
	Ceiling Insulation	11,652	595.98	9,770	4.4	Yes
	Multi-Set Back	4,661	164	2,689	3.1	Yes
	Zone Control	9,045	124	2.033	1.2	Yes
	Inside Insulation	72,266	933.61	15,305	1.1	Yes
622	Outside Air Reduction	817	333.59	7,758	35.3	Yes
(Libr)	Hot Water Temp Reduction	6	2.19	51	18.8	Yes
	Multi-Set Back	2,899	207.95	15,996	6.3	Yes
	Enthalpy Economizer	3,667	218	5,073	4.2	Yes
622	Multi-Set Back	864	59.04	-	6.0	Yes
(Bowl)						
624	Hot Water Temp Reduction	6	21.43	371	218.2	Yes
	Piping Insulation	341	56.33	1,115	15.6	Yes
	Ceiling Insulation	2,665	195.36	3,386	6.5	Yes
	Multi-Set Back	4,661	164	2,689	3.1	Yes
	Roof Insulation	56,748	1108.08	19,204	1.7	Yes
	Zone Control	9,045	124	2,033	1.2	Yes
	Inside Insulation	72,266	861.71	14,934	1.1	Yes
626	Outside Air Reduction	191	138	3,538	62.8	Yes
	Air Volume Reduction	1,042	41	1,051	2.8	Yes
	Multi-Set Back	9,837	182	4,513	1.6	Yes
628	Ceiling Insulation	2,697	177.99	28,252	6.6	Yes
	MSB/ZC Combination	4,405	210	33,333	4.9	Yes
630	Zone Control	3,012	31.0	3,734	1.1	Yes

TABLE 2

		COST	SAVII	NGS		
Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}^2}{\text{YR}}$	SIR	Feasible? (Yes/No)
632	Zone Control/Multi-Set Back	6,742	270.2	6,464	3.5	Yes
	Ceiling Insulation	12,402	151.30	3,620	1.1	Yes
635	Ceiling Insulation	3,708	190.64	21,913	4.5	Yes
639	Multi-Set Back	425	1,489.4	42,676	289.9	Yes
	Piping Insulation	183	10.64	304	5.1	Yes
	Hot Water Temp Reduction	584	22.63	648	3.4	Yes
	Ceiling Insulation	4,986	127.61	3,656	2.2	Yes
	Enthalpy Economizer	4,002	126.8	3,633	2.2	Yes
	Outside Air Reduction	534	9.4	269	1.2	Yes
	Zone Control	53,285	716.04	20,517	1.2	Yes
	Bay Door W/S	1,099	29.43	843	1.2	Yes
648	Multi-Set Back	1,585	277.00	27,700	15.4	Yes
	Ceiling Insulation	17,426	662	66,200	3.3	Yes
	Zone Control	2,010	64.00	6,038	2.8	Yes
650	Multi-Set Back	144	90.00	20,455	64.6	Yes
	Duct Insulation	99	7.27	1,652	6.5	Yes
	Ceiling Insulation	1,620	99.06	22,514	6.3	Yes
	Piping Insulation	94	1.67	380	1.7	Yes
	Inside Insulation	8,171	80.67	18,334	1.0	Yes
652	Piping Insulation	48	5.65	856	11.1	Yes
	Ceiling Insulation	1,451	123.45	18,705	8.8	Yes
	Inside Insulation	13,860	198.55	30,083	1.5	Yes
	Personnel Door W/S	232	6.20	939	1.4	Yes
654	Piping Insulation	74	11.55	1,343	14.7	Yes
	Ceiling Insulation	1,451	123.45	14,355	8.8	Yes
•	Inside Insulation	13,860	198.55	23,087	1.5	Yes
	Personnel Door W/S	232 Sum-8	6.20	721	1.4	Yes

TABLE 2

)			COST	SAVI	NGS		
	Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}^2}{\text{YR}}$	_SIR_	Feasible? (Yes/No)
	655	Hot Water Temp Reduction	6	5.43	28	49.0	Yes
		Multi-Set Back	10,609	2,712	14,125	22.5	Yes
		Ceiling Fans	3,909	303.22	1,579	6.9	Yes
		Enthalpy Economizer	5,724	451	2,349	5.6	Yes
		Outside Air Reduction	1,000	62.7	326	4.6	Yes
		CV to VAV	45,423	2,030.4	10,575	3.5	Yes
		Air Volume Reduction	95,395	2,752.34	14,335	2.1	Yes
		Induction Kitchen Hood	33,798	791.00	4,120	1.9	Yes
		Zone Control	90,603	1,581.2	8,235	1.2	Yes
		Bay Door W/S	1,151	28.23	147	1.1	Yes
		Heat Recovery	53,035	810.3	4,220	1.0	Yes
	656	Piping Insulation	119	16.22	2,534	14.1	Yes
		Ceiling Insulation	1,451	123.45	19,289	8.8	Yes
		Inside Insulation	13,860	198.55	31,023	1.5	Yes
		Personnel Door W/S	232	5.48	856	1.3	Yes
	658	Ceiling Insulation	639	40.25	15,481	6.3	Yes
		Duct Insulation	51	2.00	769	3.5	Yes
	662	Multi-Set Back	940	83.00	12,206	9.1	Yes
		Ceiling Insulation	1,451	93.49	13,749	6.4	Yes
		Piping Insulation	228	6.17	907	2.5	Yes
		Inside Insulation	13,860	145.46	21,391	1.1	Yes
	663	Hot Water Temp Reduction	6	16.56	180	149.4	Yes
		Ceiling Fans	22,646	1,124.67	12,237	4.5	Yes
	664	Multi-Set Back	144	30	4,412	21.5	Yes
		Piping Insulation	130	23.22	3,415	16.7	Yes
1		Ceiling Insulation	1,451	91.45	13,449	6.5	Yes
		Personnel Door W/S	174	3.44	506	1.1	Yes
		Inside Insulation	13,860 Sum-9	147.07	21,628	1.1	Yes

TABLE 2

,			COST	SAVII	NGS		
	Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}2}{\text{YR}}$	SIR	Feasible? (Yes/No)
	665	Ceiling Insulation	16,907	1187.63	35,033	6.2	Yes
		Inside Insulation	7,040	143.33	4,228	1.8	Yes
	666	Multi-Set Back	144	51.00	19,615	38.7	Yes
		Ceiling Insulation	639	37.47	14,412	5.8	Yes
		Duct Insulation	85	4.94	1,900	5.1	Yes
	667	Hot Water Temp Reduction	12	24.44	130	84.8	Yes
		Outside Air Reduction	267	18	96	4.8	Yes
		Piping Insulation	158	6.6	35	3.7	Yes
		Multi-Set Back	71,883	1,122	6,543	1.4	Yes
	668	Ceiling Insulation	1,619	102.13	24,910	6.5	Yes
)		Duct Insulation	72	3.06	746	3.7	Yes
		Piping Insulation	219	3.36	820	1.4	Yes
		Inside Insulation	8,144	84.30	20,561	1.1	Yes
		Air Volume Reduction	3,443	23.00	5,610	1.0	Yes
	670	Hot Water Temp Reduction	6	2.08	184	21.2	Yes
		Piping Insulation	340	64.80	5,735	19.7	Yes
		Zone Control	4,291	82	13,903	2.0	Yes
	671	Multi-Set Back	863	116.48	43,141	11.9	Yes
		Ceiling Insulation	682	39.98	14,807	5.2	Yes
	671A	Multi-Set Back	863	132.60	49,111	13.5	Yes
		Ceiling Insulation	682	37.81	14,004	4.9	Yes
	681	Outside Air Reduction	267	81.00	2,040	26.4	Yes
		Multi-Set Back	1,436	297.00	7,481	18.2	Yes
		Zone Control	7,216	133.00	3,350	1.6	Yes

TABLE 2

		COST	SAVI	NGS		
Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}2}{\text{YR}}$	SIR	Feasible? (Yes/No)
684	Piping Insulation	34	3.49	1,058	9.6	Yes
	Multi-Set Back	863	52.56	15,927	5.7	Yes
	Ceiling Insulation	638	35.16	10,655	5.1	Yes
	Duct Insulation	38	0.91	276	2.0	Yes
	Inside Insulation	8,171	86.62	26,248	1.0	Yes
685	Hot Water Temp Reduction	6	5.21	82	53.0	Yes
	Air Volume Reduction	727	190.00	2,547	18.5	Yes
	Piping Insulation	356	58.48	925	15.4	Yes
	Ceiling Insulation	6,357	744.34	11,778	10.1	Yes
	Enthalpy Economizer	1,797	254.00	4,019	10.0	Yes
	Induction Kitchen Hood	6,185	216.41	3,424	3.1	Yes
	High Efficiency Fluorescent	43,989	964.2	15,257	1.2	Yes
	Multi-Set Back	35,404	452.00	7,152	1.1	Yes
687	Pipe Insulation	369	24.93	394	5.95	Yes
	Ceiling Insulation	40,785	631.21	9,987	1.4	Yes
	Inside Insulation	62,854	722.54	11,432	1.0	Yes
689	Multi-Set Back	431	208.25	22,392	42.5	Yes
692	Multi-Set Back	863	109.01	31,146	13.1	Yes
	Boiler Replacement	4,071	40.61	11,603	1.0	Yes
693	Ceiling Insulation	2,642	155.60	19,949	6.1	Yes
	Multi-Set Back	1,806	96.62	12,387	5.5	Yes
	Boiler Replacement	4,071	91.31	11,706	1.6	Yes
	Inside Insulation	18,265	240.29	30,806	1.4	Yes

TABLE 2

		COST	SAVI	1GS		
Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}2}{\text{YR}}$	SIR	Feasible? (Yes/No)
705	Multi-Set Back	3,417	2,749.38	64,539	83.2	Yes
	Piping Insulation	27	3.73	88	13.0	Yes
705 A	Multi-Set Back	3,417	1,418.49	43,503	42.9	Yes
706	Personnel Door W/S	123	7.36	898	3.3	Yes
719	Outside Insulation	17,238	211.65	50,393	1.1	Yes
720	Piping Insulation	432	90.56	2,736	18.4	Yes
	Multi-Set Back/Zone Control	57,612	715.88	21,628	1.1	Yes
721	Ceiling Insulation	75	10.64	1,935	14.5	Yes
	Piping Insulation	81	9.86	1,793	12.6	Yes
	Inside Insulation	4,690	180.36	32,793	4.0	Yes
	Bay Door W/S	1,454	57.69	10,489	2.1	Yes
727	Hot Water Temp Reduction	18	25.62	66	64.2	Yes
	Air Volume Reduction and Outside Air Reduction	44,775	24,051.75	62,037	49.5	Yes
733	Multi-Set Back	861	82.87	18,015	9.9	Yes
745 (A&B)	Air Volume Reduction & Outside Air Reduction	11,011	3,747.82	3,859	29.8	Yes
	Heat Recovery	20,332	782.92	806	3.4	Yes
	Induction Kitchen Hood	289,971	6,489.43	6,682	2.0	Yes
751	Hot Water Temp Reduction	6	28.89	232	260.6	Yes

TABLE 2

		COST	SAVI	NGS		
Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}2}{\text{YR}}$	SIR	Feasible? (Yes/No)
752	Outside Air Reduction	15,385	3,596.56	18,673	20.4	Yes
	Air Volume Reduction	2,457	390.26	2,026	11.6	Yes
	Enthalpy Economizer	6,036	156.40	812	2.1	Yes
	Ceiling Insulation	21,916	369.66	1,919	1.5	Yes
	Inside Insulation	211,188	3,419.58	17,755	1.4	Yes
753	Multi-Set Back	15,877	9,416.7	45,823	52.2	Yes
	Air Volume Reduction and					
	Outside Air Reduction	10,573	1,580.45	7,690.	12,6	Yes
	Ceiling Insulation	5,052	385.30	1,875	6.5	Yes
756	Hot Water Temp Reduction	6	6.25	20	56.4	Yes
	Floor Insulation	6,171	120.28	394	1.7	Yes
	Zone Control*	85,520	1,195	3,915	1.2	Yes
	Multi-Set Back	275,415	3,841	12,585	1.2	Yes
	* "Zone Control" duplicated i	n "Multi-Set Bac	ek" project.			
757	Hot Water Temp Reduction	6	3.61	34	32.6	Yes
	Air Volume Reduction and Outside Air Reduction	14,032	4,335.55	41,290	25.7	Yes
	Multi-Set Back	10,726	1,892.11	18,020	14.3	Yes
759	Hot Water Temp Reduction	6	3.89	360	33.0	Yes
	Ceiling Insulation	3,546	83.73	7,753	2.0	Yes
	High Efficiency Fluorescent	812	18.7	1,731	1.3	Yes
783	Ceiling Insulation	3,889	593.05	74,131	13.4	Yes
	Multi-Set Back	431	36.72	4,590	7.5	Yes
785	Ceiling Insulation	5,145	363.43	18,734	7.3	Yes
	Multi-Set Back	9,216	241.3	12,438	2.7	Yes

TABLE 2

		COST	SAVI	NGS		
Bldg.	Energy Conservation Measure	Const Costs (\$)	Annual MBTU/YR	$\frac{\text{BTU/FT}2}{\text{YR}}$	SIR	Feasible? (Yes/No)
793	Heat Recovery	111,051	1,342	55,226	1.1	Yes
795	Heat Recovery	111,051	1,343	55,262	1.1	Yes
900	Multi-Set Back	1,412	3,792.4	26,896	213.2	Yes
	Air Volume Reduction and Outside Air Reduction	18,638	14,370.27	101,916	60.4	Yes
	Optimize Off Coil Temp	56,339	7,435.3	52,732	11.6	Yes
	Enthalpy Economizer	24,145	1,548.4	10,981	5.5	Yes
	Induction Kitchen Hood	59,272	1,912.65	13,564	2.9	Yes
	Bay Door W/S	767	34.99	248	2.1	Yes
	Heat Recovery	11,080	229.30	1,626	1.9	Yes
	CV to VAV	900,000	21,305.38	151,101	1.8	Yes
	High Efficiency Fluorescent	147,016	3,821	27,099	1.4	Yes
901	Multi-Set Back	431	20.19	2,804	4.8	Yes

TAIN 3 SUMMARY OF RESULTS OF FEASIBLE PROJECTS PACKAGED AS 1391 OR 4283

Priority No.	Energy Conservation Opportunity Title	No. of Bldgs. Affected	Construction Cost (X \$1,000)	Annua Energy (MBTU)	Annual Savings gy Cost (Y \$1,000)	Overall SIR	Document Type
	Outside Air & Air Volume Reduction	17	263	65,804	425	20.8	1391
2	Hot Water Temperature Reduction	17	0.7	213	г	14.3	4283
3	Optimize Off-Coil Temperature		56	7,435	47	11.6	1391
4	Pipe Insulation	19	4	480	က	10.7	4283
5	Ceiling Fans	2	22	1,428	6	4.8	1391
9	Duct Insulation	5	0.3	18	0.1	4.6	4283
7	Enthalpy Economizer	8	84	4,480	29	4.3	1391
88	Zone Control/ Multiple Set Back	38	751	36,405	247	4.3	1391
6	Ceiling/Roof Insulation	30	190	7,745	53	3.7	1391
10	Induction Kitchen Hood	5	411	11,128	02	2.4	1391
11	Constant Volume to Variable Air Volume Conversion	2	945	23,336	. 156	1.9	1391
12	Boiler Replacement	2	8	132	1	1.7	4283
13	Floor Insulation	Ţ	9	120	8*0	1.7	1391
14	Bay Door & Personnel Door Weatherstripping	6	υ.	179	1	1.6	4283

Priority No.	Energy Conservation Opportunity Title	No. of Bldgs. Affected	Construction Cost (X \$1,000)	Annua Energy (MBTU)	Annual Savings ergy Cost BTU) (X \$1,000)	Overall SIR	Document Type
15	Lighting Modifications	4	197	4,962	34	1.4	1391
16	Inside/Outside Wall Insulation	17	592	8,223	56	1.4	1391
17	Heat Recovery	2	298	4,508	28	1.3	1391
	TOTAL		3,838	176,596	1,161		

A.

6,